

## IVM Controller Exercise

1. Controller – ESP-LX IVM
2. 30 Stations
3. Flow Rate: 5 GPM for All Stations
4. Cycle: 5 Minutes
5. Soak: 10 Minutes
6. Base Run Time for Stations 1-30: 25 minutes
7. Station Priority:
  - a. 1-18: High
  - b. 19-20: Medium
  - c. 21-30: Low
8. Program Adjust: 110%
9. Weather Sensor #1: Rain Shutoff Device (RSD): Normally Closed – Rain (Alarm)
10. Controller Simulstations: 8
11. Program #1 Simulstations: 8
12. Master Valve: Normally Closed
13. Flow Sensor: FS200P
14. Flow Zone: 1
15. Flow Zone 1 Flow Rate: 55 GPM
16. Flow Watch: On; SEEF 160%, Settle 5 Minutes / SELF 65%, Settle 6 Minutes – Each Diagnose & Eliminate
17. FloManager: On
18. Start Times: 10:00 PM
19. Start Days: Odd-31
20. Water Window: 10:00 PM to 6:00 AM